

**SOUTH GRANVILLE WATER and SEWER AUTHORITY
2013-2014 SYSTEM PERFORMANCE
ANNUAL REPORT**

I. General Information

Facility/System Name: South Granville Water and Sewer Authority Wastewater Treatment Plant
Responsible Entity: South Granville Water and Sewer Authority
Person in Charge/Contact: Wilmer Lawson
 South Granville Water and Sewer Authority
 415-B Central Avenue
 Butner, NC 27509
 (919) 575-3111
Applicable Permit(s): NPDES Permit No. NC0026824

Description of Treatment Process and Collection System:

- A. The design capacity of the wastewater treatment plant is 5.5 mgd. This facility consists of fine screening, extended aeration, biological nutrient removal, clarification, tertiary filtration, chlorination, dechlorination, sludge thickening, two-stage digestion and disposal of sludge by land application.
- B. The South Granville Water and Sewer Authority wastewater collection system consists of approximately 25-miles of force main and 50 miles of gravity flow pipe ranging from 8 to 30 inches in diameter. There are 33 pumping stations in the system, which lift wastewater from lower areas up to the main outfall lines to the wastewater treatment plant. Each pumping station is equipped with a standby generator for emergency power and a SCADA system to monitor pumping station conditions and standby generator status. The wastewater collection system for the South Granville Water and Sewer Authority was constructed in the 1940's.

II. Performance

Summary of System Performance for Fiscal Year July 1, 2013 thru June 30, 2014

The South Granville Water and Sewer Authority Wastewater Treatment Plant operates under NPDES Permit No. NC0026824 with the following permit limitations:

<u>Parameter</u>	<u>Permitted Level</u>
Flow	5.5 MGD
Biological Oxygen Demand	5 mg/L summer, 10mg/L winter
Total Suspended Residue	30 mg/L
Ammonia	2 mg/L summer, 4 mg/L winter
Dissolved Oxygen	6 mg/L minimum
Fecal Coliform	200/100 ml
Total Phosphorus	2 mg/L Quarterly Average
Total Nitrogen	58,599 lbs/year
Total Antimony	6.0 ug/L monthly
Total Mercury	0.012 ug/L Quarterly average
PH	6 minimum 9 maximum Standard Unit
Chronic Toxicity	Pass/Fail 90% Chronic (Ceriodaphnia)
Total Residual Chlorine	17.0 ug/L

A review of the discharge monitoring reports for the period of July 2013 through June 2014 was conducted. The next page is a monthly list of the number and type of all violations of permit limits, monitoring and reporting violations, illegal bypass of treatment facilities and sanitary sewer overflows.

	Permit Limit		Illegal Bypass of Treatment Facilities		Sanitary Sewer Overflows Estimated Total		
	Month	Type	Qty	Type	Qty	Volume/Gallons	Location
July			0		0	0	
August			0		0	0	
September			0		0	0	
October			0		0	0	
November			0		0	0	
December			0		0	0	
January			0		0	0	
February			0		0	0	
March			0		0	0	
April			0		0	0	
May			0		0	3200	Wastewater Treatment Plant
June			0		0	0	

III. Industrial Pretreatment/ FOG Program

Industrial Pretreatment Program staff surveys facilities discharging into the sewer system and issue permits to facilities in certain categories, determined either by the type of business activity they conduct or the type(s) of wastewater discharged from their facility. Permit limits are established based on the ability of the receiving SGWASA Wastewater Treatment Plant. SGWASA currently monitors (1) industrial user.

FOG (fats, oil and grease) refers to all fats, oils and grease generated during food preparation, food service, and/ or kitchen cleanup. Residents can help prevent pipe blockages and sewer overflows by keeping grease out of the sewer system. Sewer backups can cause damage to homes, health hazards and threaten the environment. Sewer pipes blocked by grease have become an increasing cause of SGWASA Sewer System’s overflows. Working together, we can prevent sewer overflows and keep the environment clean.

What can residents do?

- Never pour grease down the sink or into the toilet.
- Scrape grease and food scraps into a waste container after it cools.
- Do not put food scraps down the garbage disposal. Garbage disposal units do not prevent grease from going down the drain.
- Use a strainer in the sink to catch food scraps and other solids.

IV. Notification

A list was developed from customer billing records and each customer was directed to the SGWASA website where they could view a copy of the Performance Annual Report as part of the monthly bill in August 2014.

V. Certification

I certify under penalty of law that this report is complete and accurate to the best of my knowledge. I further certify that this report has been made available to the users or customers of the named system and that those users have been notified of its availability.



Lindsay L. Mize, Executive Director
 415-B Central Avenue
 Butner, NC 27509